

**SAVE THESE INSTRUCTIONS!**  
**READ CAREFULLY AND FOLLOW ALL INSTRUCTIONS FOR YOUR OWN SAFETY**

- **DISCONNECT AC POWER SUPPLY BEFORE SERVICING.**
- Installation and servicing of this equipment should be performed by qualified service personnel only.
- Ensure the electrical connections conform to the National Electrical Code and local regulations if applicable.
- Do not mount near gas or electrical heaters.
- Equipment should be mounted in locations and at heights where it will not readily be subjected to tampering by unauthorized personnel.
- The use of accessory equipment not recommended by the manufacturer may cause an unsafe condition. Any modification or use of non-original components will void the warranty and product liability.
- Do not use this equipment for other than intended use.

**INSTALLATION INSTRUCTIONS**

1. Trace then cut a 6" x 9" rectangular hole in the ceiling or wall.
2. Knock out the appropriate mounting holes and secure flexible conduit, to backbox.
3. Electrical connections should be made in wireway box. Cap unused wire to prevent shorting.

**120V AC**

White - Common  
Black - 120V  
Green - Ground

**277V AC**

White - Common  
Orange - 277V  
Green - Ground

4. Secure in place using cables, chain or mounting against the wall. Use appropriate hardware for application such as wood or concrete screws.
5. Connect lamp leads from the control board (located inside backbox) to lamp enclosure assembly.
6. Place supplied nylon spacers on threaded studs located inside of backbox.

7. Insert lamp enclosure assembly into wall cutout and secure in place using lamp enclosure nuts.
8. Energize un-switched AC power to unit. verify indicator light is illuminated.
9. Press test button and verify hinged doors open and the lamps turn on.

Note: If lamps do not illuminate, allow unit to charge for 30 mins.

